



Utah Tech University

Food Truck Inspection



Date: _____
Vendor: _____
Address: _____
City, ST Zip _____

Contact name: _____
Contact number: _____
License: _____
VIN: _____

#	Inspection Step	Compliant		Comments
		Yes	No	
LPG containers and piping				
1	LPG piping is code compliant.			
2	Approved LPG containers.			
3	Containers installed outside or in vapor tight cabinets accessible from outside.			
4	LPG containers are mounted securely.			
5	Containers protected against impact.			
6	Protection of cylinder valve.			
7	Shut off valve is readily accessible.			
8	Flexibility between regulator and fixed piping.			
9	LPG cylinders shall not be installed, transported, or stored inside the vehicle.			
10	No fueling or tank exchange during event or with public present.			
LPG appliances				
11	All appliances installed on vehicles shall be approved.			
12	Appliances shall be readily accessible.			
13	Appliances shall be protected to minimize damage in transit.			
14	Appliances shall not block egress.			
15	Install permanent caution plate.			
Hood system				
16	Type 1 hood with grease laden vapors			
17	Fire extinguishing system in hood with tag.			
18	Proper ventilation and grease filters.			
19	Hood cleaned at regular intervals.			
20	Extinguishing system serviced every 6 mo.			
Fire extinguishers				
21	All cooking vehicles have at least a 2A10BC extinguisher.			
22	Class K extinguisher is present if hood is required.			
Out of service				
23	LPG system shall be leak free.			
24	Cylinders and/or containers shall be closed.			
25	Vehicle shall not be parked near heat sources, open flame, other ignition sources.			
Fire apparatus access roads				
26	Fire apparatus access roads shall not be obstructed.			
Electrical safety				
27	Electrical hazards shall be abated.			
28	Electrical panels shall be accessible.			
29	Extension cords shall not replace permanent wiring.			
30	No open junction boxes.			
31	Safe use of generators.			
General requirements				
32	No smoking sign is posted.			
33	No public personnel in vehicle.			
34	Business license is posted.			
35	No fueling during event or with public present.			
36	LPG gas detector is installed.			

Inspector name: _____

Inspector signature: _____

PASS

FAIL

THIS FORM IS NOT VALID UNLESS IT HAS BEEN REVIEWED, APPROVED, AND SIGNED BY APPROPRIATELY TRAINED/LICENSED UTAH TECH PERSONNEL OR OTHER APPOINTED TRAINED/LICENSED PERSONNEL CONTRACTED BY UTAH TECH UNIVERSITY.

Please see reverse side

COMMENTS
